

Kaushalya Estate Pvt. Ltd.

Regd. Off. : 2H/33, Near T. V. Tower, Gandhi Nagar, Kankarbagh, Patna-26
Mob. : 9473400996, 7739471800

BINDER CONTENT FOR TEST METHOD : IRC : SP-II

Name of Road : P/R work in Km-0.00 to 34.00 of NH-333A

Location : H.M.P. site Sikandra for km-33

Name of Work : B.C.I

Agreement No. : 16/SBD/16-17 Date : 30-4-2017

job No - TA-333A - BR-2016-17/1546

OBSERVATIONS

Sl. No.	Description	Sample 1	Sample 2	Sample 3
1	2	3	4	5
1	Weight of mix W (gm)	506.45	512.82	/
2	Weight of sample (Bowl+Mix) before extraction, W1 (gm)	565.35	571.72	
3.	Weight of sample (Bowl+Mix) ^{after} before extraction, W2 (gm)	537.23	543.76	
4.	Weight of filter paper extraction, W3 (gm) Before	7.22	8.34	
5.	Weight of filter paper after extraction, W4 (gm)	7.38	8.55	
6.	Bitumen content by wt, Pf mix % =[W1-W2] - (W4-43)]/Wx100	5.52%	5.41%	

Remarks.....

Letter No. Date.....

Copy to : 1. Assistant Engineer, N.H. Sub Division, Biharsharif
2. Executive Engineer, N.H. Div. No.-2 Biharsharif

Neehmami

Tested By

Checked By

Kaushalya Estate Pvt. Ltd.

Regd. Off. : 2H/33, Near T. V. Tower, Gandhi Nagar, Kankarbagh, Patna-20
Mob. : 9473400996, 7739471800

BINDER CONTENT FOR TEST METHOD : IRC : SP-II

Name of Road : P/R work in km - 0.00 to 34.00 of NH-333A

Location : H.M.A. Site Sikandra for km-32

Name of Work : B.C. I

Agreement No. : 16/SB2/16-17

Date : 02-05-2017

Job No. : TA-333A-BR-2016-17/1546

OBSERVATIONS

Sl. No.	Description	Sample 1	Sample 2	Sample 3
1	2	3	4	5
1	Weight of mix W (gm)	515.67	521.22	
2	Weight of sample (Bowl+Mix) before extraction, W1 (gm)	574.57	580.12	
3.	Weight of sample (Bowl+Mix) before after extraction, W2 (gm)	546.05	551.55	
4.	Weight of filter paper extraction, W3 (gm) Before	6.88	7.31	
5.	Weight of filter paper after extraction, W4 (gm)	7.05	7.47	
6.	Bitumen content by wt, Pf mix % =[W1-W2] - (W4-43)/Wx100	5.497%	5.45%	

Remarks.....

Letter No. Date.....

Copy to : 1. Assistant Engineer, N.H. Sub Division, Biharsharif
2. Executive Engineer, N.H. Div. No.-2 Biharsharif

Neehmani
Tested By

Checked By