

**BALKRISHNA BHALOTIA CONSTRUCTION PVT. LTD.**

NAME OF WORK :-

NEMDARGANJ-RAMJANPUR ROAD (Km 0.00 - 9.60) under  
CMBD

LOCATION :-

Cement Concrete Pavement

**SLUMP TEST**

Details (In Chainage)	Date of Testing	Height of the Mould (In Cm)	Height of the Concrete after Removing the Mould (In Cm)	Slump for the Concrete (In Cm)
9.550Km	10.02.17	30	26.2	3.8
9.400Km	15.02.17	30	26.1	3.9
5.000Km	20.02.17	30	26.4	3.6
4.600Km	25.02.17	30	26.3	3.7

R  
25.2.17

Lab Assistant

B.K. Bhalotia Const. Pvt. Ltd.

Rashad  
25.2.17  
Site Engineer

B.K. Bhalotia Const. Pvt. Ltd.

A  
25.2.17  
JBAS  
A. Bhalotia  
25.2.17  
ME

**BALKRISHNA BHALOTIA CONSTRUCTION PVT. LTD.**

NAME OF WORK :- NEMDARGANJ-RAMJANPUR ROAD (Km 0.00 - 9.60) under CMBD  
LOCATION :- 4.000Km. RCC Culvert

**SLUMP TEST**

Details	Date of Testing	Height of the Mould (In Cm)	Height of the Concrete after Removing the Mould (In Cm)	Slump for the Concrete (In Cm)
Abutment Cap	22.01.17	30	24.3	5.8
Deck Slab	30.01.17	30	27.1	2.9

*P2*  
*30.1.17*

Lab Assistant  
B.K. Bhalotia Const. Pvt. Ltd.

*Rasheed*  
*30.01.17*

Site Engineer  
B.K. Bhalotia Const. Pvt. Ltd.

*Red*  
*30.1.17*  
*JE*

*q/s*  
*B. Bhalotia*  
*30-1-17*  
*AE*

**BALKRISHNA BHALOTIA CONSTRUCTION PVT. LTD.**

NAME OF WORK :- NEMDARGANJ-RAMJANPUR ROAD (Km 0.00 - 9.60) under CMBD

LOCATION :- 3.800Km. RCC Culvert

**SLUMP TEST**

Details	Date of Testing	Height of the Mould (In Cm)	Height of the Concrete after Removing the Mould (In Cm)	Slump for the Concrete (In Cm)
Abutment Cap	14.02.17	30	24.3	5.7
Deck Slab	20.02.17	30	27.3	2.8

*Pz*  
20.2.17

Lab Assistant  
B.K. Bhalotia Const. Pvt. Ltd.

*Rasheed*  
20.02.17  
Site Engineer

B.K. Bhalotia Const. Pvt. Ltd.

*AE*  
20.2.17  
JE

*AE*  
*S. Rayal*  
25-2-17

4/6

**BALKRISHNA BHALOTIA CONSTRUCTION PVT. LTD.**

NAME OF WORK :- NEMDARGANJ-RAMJANPUR ROAD (Km 0.00 - 9.60) under  
CMBD  
LOCATION :- 2.150Km. RCC Culvert

**SLUMP TEST**

Details	Date of Testing	Height of the Mould (In Cm)	Height of the Concrete after Removing the Mould (In Cm)	Slump for the Concrete (In Cm)
Abutment Cap	18.02.17	30	24.4	5.6
Deck Slab	25.02.17	30	27.1	2.9

*P*  
25.2.17

Lab Assistant  
B.K. Bhalotia Const. Pvt. Ltd.

*Parshad*  
25.02.17

Site Engineer  
B.K. Bhalotia Const. Pvt. Ltd.

*AE*  
25.2.17  
JE

*CS*  
D. Rayal  
AE 25-2-17

**BALKRISHNA BHALOTIA CONSTRUCTION PVT. LTD.**

NAME OF WORK :- NEMDARGANJ-RAMJANPUR ROAD (Km 0.00 - 9.60) under CMBD

LOCATION :- 0.250Km. RCC Culvert

**SLUMP TEST**

Details	Date of Testing	Height of the Mould (In Cm)	Height of the Concrete after Removing the Mould (In Cm)	Slump for the Concrete (In Cm)
Abutment Cap	13.01.17	30	24.1	5.9
Deck Slab	19.01.17	30	27.2	2.8

*P*  
19.1.17

Lab Assistant  
B.K. Bhalotia Const. Pvt. Ltd.

*Rashad*  
19.01.17

Site Engineer  
B.K. Bhalotia Const. Pvt. Ltd.

*Ata*  
19.1.17  
JE

*CLS*  
*L. Rayal*  
AE 301-18

**BALKRISHNA BHALOTIA CONSTRUCTION PVT. LTD.**

NAME OF WORK :- NEMDARGANJ-RAMJANPUR ROAD (Km 0.00 - 9.60) under CMBD  
LOCATION :- 0.040Km. RCC Culvert

SLUMP TEST

Details	Date of Testing	Height of the Mould (In Cm)	Height of the Concrete after Removing the Mould (In Cm)	Slump for the Concrete (In Cm)
Abutment Cap	31.01.17	30	24.2	5.8
Deck Slab	13.02.17	30	27.3	2.7

*P*  
13.2.17

Lab Assistant

B.K. Bhalotia Const. Pvt. Ltd.

*Ranveer*  
13.02.17

Site Engineer

B.K. Bhalotia Const. Pvt. Ltd.

*A*  
13.2.17  
JE

*9/5*  
*L. Rajpal*  
25-2-17