

BALKRISHNA BHALOTIA CONSTRUCTION PVT. LTD.

NAME OF WORK :-

NEMDARGANJ-RAMJANPUR ROAD (Km 0.00 - 9.60) under CMBD

LOCATION :-

4.000Km. RCC Culvert

FINENESS OF CEMENT (PORTLAND POZZOLONA CEMENT)

Wt. of Sample (In Gram)	Date of Testing	Wt. Retained Quantity (In Gram)	% Wt. of Residue Quantity
100	27.12.16	4.700	4.70
100	27.12.16	4.580	4.58
100	27.12.16	4.450	4.45

Pr
27.12.16

Lab Assistant

B.K. Bhalotia Const. Pvt. Ltd.

Prashant
27.12.16

Site Engineer

B.K. Bhalotia Const. Pvt. Ltd.

Pr
27.12.16
JEC/S
S. Nayak
29.12.16
HE

BALKRISHNA BHALOTIA CONSTRUCTION PVT. LTD.

NAME OF WORK :- NEMDARGANJ-RAMJANPUR ROAD (Km 0.00 - 9.60) under CMBD

LOCATION :- 3.800Km. RCC Culvert

FINENESS OF CEMENT (PORTLAND POZZOLONA CEMENT)

Wt. of Sample (In Gram)	Date of Testing	Wt. Retained Quantity (In Gram)	% Wt. of Residue Quantity
100	01.02.17	4.710	4.71
100	01.02.17	4.590	4.59
100	01.02.17	4.460	4.46

Pz
1.2.17

Lab Assistant

B.K. Bhalotia Const. Pvt. Ltd.

Roshaaf
1.02.17

Site Engineer

B.K. Bhalotia Const. Pvt. Ltd.

AE
1.2.17
JE

CS
S. Nayal
AE 06-02-17

BALKRISHNA BHALOTIA CONSTRUCTION PVT. LTD.

NAME OF WORK :- NEMDARGANJ-RAMJANPUR ROAD (Km 0.00 - 9.60) under CMBD
LOCATION :- 2.150Km. RCC Culvert

FINENESS OF CEMENT (PORTLAND POZZOLONA CEMENT)

Wt. of Sample (In Gram)	Date of Testing	Wt. Retained Quantity (In Gram)	% Wt. of Residue Quantity
100	10.01.17	4.720	4.72
100	10.01.17	4.610	4.61
100	10.01.17	4.480	4.48

P
10.1.17

Lab Assistant
B.K. Bhalotia Const. Pvt. Ltd.

Ranshad
10.01.17

Site Engineer
B.K. Bhalotia Const. Pvt. Ltd.

A
10.1.17
JE.

C/S
A. Dayal
AE 20-1-17

BALKRISHNA BHALOTIA CONSTRUCTION PVT. LTD.

NAME OF WORK :- NEMDARGANJ-RAMJANPUR ROAD (Km 0.00 - 9.60) under CMBD
LOCATION :- 0.250Km. RCC Culvert

FINENESS OF CEMENT (PORTLAND POZZOLONA CEMENT)

Wt. of Sample (In Gram)	Date of Testing	Wt. Retained Quantity (In Gram)	% Wt. of Residue Quantity
100	29.12.16	4.750	4.75
100	29.12.16	4.630	4.63
100	29.12.16	4.510	4.51

M
29.12.16

Lab Assistant

B.K. Bhalotia Const. Pvt. Ltd.

Roshan
29.12.16

Site Engineer

B.K. Bhalotia Const. Pvt. Ltd.

AE
29.12.16
JE.

c/s
S. Doyal
29-12-16
AE

BALKRISHNA BHALOTIA CONSTRUCTION PVT. LTD.

NAME OF WORK :- NEMDARGANJ-RAMJANPUR ROAD (Km 0.00 - 9.60) under CMBD
LOCATION :- 0.040Km. RCC Culvert

FINENESS OF CEMENT (PORTLAND POZZOLONA CEMENT)

Wt. of Sample (In Gram)	Date of Testing	Wt. Retained Quantity (In Gram)	% Wt. of Residue Quantity
100	18.01.17	4.770	4.77
100	18.01.17	4.650	4.65
100	18.01.17	4.540	4.54

Pr
18.1.17

Lab Assistant
B.K. Bhalotia Const. Pvt. Ltd.

Rashad
18.01.17

Site Engineer
B.K. Bhalotia Const. Pvt. Ltd.

AE
18.1.17
JE

C/S
S. D. Dey
AE 20-1-17

BALKRISHNA BHALOTIA CONSTRUCTION PVT. LTD.

NAME OF WORK :- NEMDARGANJ-RAMJANPUR ROAD (Km 0.00 - 9.60) under CMBD

LOCATION :- 0.900Km. RCC Culvert

FINENESS OF CEMENT (PORTLAND POZZOLONA CEMENT)

Wt. of Sample (In Gram)	Date of Testing	Wt. Retained Quantity (In Gram)	% Wt. of Residue Quantity
100	05.02.17	4.780	4.78
100	05.02.17	4.630	4.63
100	05.02.17	4.620	4.62

Pn
5.2.17

Lab Assistant

B.K. Bhalotia Const. Pvt. Ltd.

Ranshoo
5.02.17

Site Engineer

B.K. Bhalotia Const. Pvt. Ltd.

AE
5.2.17
SE

cl s
S. Dayal
AE 06-02-17

BALKRISHNA BHALOTIA CONSTRUCTION PVT. LTD.

NAME OF WORK :- NEMDARGANJ-RAMJANPUR ROAD (Km 0.00 - 9.60) under CMBD
LOCATION :- 1.600Km. RCC Culvert

FINENESS OF CEMENT (PORTLAND POZZOLONA CEMENT)

Wt. of Sample (In Gram)	Date of Testing	Wt. Retained Quantity (In Gram)	% Wt. of Residue Quantity
100	26.01.17	4.390	4.39
100	26.01.17	4.520	4.52
100	26.01.17	4.590	4.59

P
26.1.17

Lab Assistant
B.K. Bhalotia Const. Pvt. Ltd.

Darshad
26.01.17

Site Engineer
B.K. Bhalotia Const. Pvt. Ltd.

A
26.1.17
JE

ds
A. Dey
26-1-17
AE